

Town of Edgartown, MA
Wastewater Treatment Facility

INITIAL SCREENING

Please note: Design Criteria below photo



Initial Screening		
Type	Fine Screen-Mechanically Cleaned	Fine Screen-Mechanically Cleaned
No. of Units	1	1
Bar Spacing (in.)	1/4	1/4
Capacity (cu. ft/hr.)	18.8	18.8
Capacity (MGD)	2.5	2.5
Horsepower	2	2
Type - By Pass	Manually Cleaned	Manually Cleaned
No. of Units	1	1
Bar Spacing (in.)	1/2	1/2