

EDGARTOWN WATER DEPARTMENT  
58 KAVANAGH WAY  
EDGARTOWN, MA 02539 (508) 627-4717  
PWS ID #4089000



## 2022 DRINKING WATER QUALITY REPORT

The Edgartown Water Department is committed to providing our customers with water of the highest quality that meets or exceeds state and federal requirements. We are proud of the product and services we provide, and in accordance with federal drinking water regulations, we present this Water Quality Report (Consumer Confidence Report) to inform consumers about the quality of water provided over the past year. In addition to water quality information, this report includes information on the water production, treatment, storage and distribution system of the Edgartown Water Department.

---

### YOUR DRINKING WATER SYSTEM

---

The Edgartown Water Department is staffed and operated by a team of Massachusetts Certified Drinking Water Operators. To name a few, these Operators are tasked with the responsibilities of maintaining and operating the water system in a compliant manner, tending to necessary repairs and the oversight of daily operations. In addition, the water system is routinely inspected by the MassDEP to ensure that the system is compliant, free of potential hazards, financially sound and properly managed. The most recent inspection was conducted in 2021. These inspections have revealed no major deficiencies or compliance issues with management / operational practices.

The Town of Edgartown is supplied with water of the highest quality from five groundwater supplies ranging in a depth of 60 to 120 feet. Each well is enclosed in a pumping station that also serves as a water treatment facility. Machacket Well (408900-04G) is located on Machacket Road. Lily Pond Well (4089000-05G) is located on Vineyard Haven Road. Wintucket (4089000-06G) and Quenomica Wells (4089000-07G) are located on Kavanagh Way and Nunnepog Well (4089000-08G) is located on Lovewell Way. These five sources all withdraw from the Martha's Vineyard Sole Source Aquifer.

During 2022, these five sources provided 401,933,800 gallons of potable water to 3,513 residential, commercial and municipal accounts. These five sources also supply water for fire protection to 359 fire hydrants.

The Town of Edgartown's water distribution system consists of approximately 75 miles of cast iron, PVC, ductile iron and asbestos cement water mains ranging from two to sixteen inches in diameter. The town has one water storage facility – the Mill Hill Road Standpipe with a capacity of 2.2 million gallons.

While the Edgartown Water Department is considered an independent water system, there are two emergency interconnections with Oak Bluffs Water District that may be used, should either system experience a catastrophic failure or need to take their water tank out of service for maintenance or repair. The interconnections were not utilized in 2022.

Currently, the Town of Edgartown is operating a full-scale corrosion control program at all of the active well sites. Sodium hydroxide / potassium hydroxide is used to reduce the levels of lead and copper at the household tap by raising the pH of the raw water from approximately 6.0 to approximately 7.4.

## POTENTIAL SUBSTANCES FOUND IN TAP WATER

---

Sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it may dissolve naturally-occurring minerals, as well as substances resulting from the presence of human activity.

Contaminants that may be present in source water include:

**Microbial contaminants** - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

**Inorganic contaminants** - such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

**Pesticides and herbicides** - which may come from a variety of sources such as agricultural, urban storm water runoff, and residential uses.

**Organic chemical contaminants** - including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

**Radioactive contaminants** - which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the Massachusetts Department of Environmental Protection (MassDEP) and United States Environmental Protection Agency (EPA) prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) and Massachusetts Department of Public Health (DPH) regulations establish limits for contaminants in bottled water that must provide the same protection for public health. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and some infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control and Prevention (CDC) guidelines on lowering the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Edgartown Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in household plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. While the Water Department does not perform this service, we may assist and advise you accordingly. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water hotline or at <http://www.epa.gov/safewater/lead>.

## IMPORTANT DEFINITIONS

---

**Maximum Contaminant Level (MCL)** – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Treatment Technique (TT)** – A required process intended to reduce the level of a contaminant in drinking water.

**Action Level (AL)** – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**90<sup>th</sup> Percentile** – Out of every 10 homes sampled, 9 were at or below this level.

**Variations and Exemptions** – State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

**Part Per Million (ppm)** – This unit is equivalent to one milligram per liter (mg/L). One part per one million is equal to one minute in two years or one penny in \$10,000.00.

**Part Per Billion (ppb)** – This unit is equivalent to one microgram per liter (µg/L). One part per one billion is equal to one minute in two thousand years or one penny in \$10,000,000.00.

**Part Per Trillion (ppt)** – This unit is equivalent to one nanogram per liter (ng/L). One part per one trillion is equal to one square inch in 250 square miles, or one ounce in 7.5 billion gallons of water.

**Secondary Maximum Contaminant Level (SMCL)** – These standards are developed to protect the aesthetic qualities of drinking water and are not health based.

**Massachusetts Office of Research and Standards Guideline (ORSG)** – This is the concentration of a chemical in drinking water, at or below which, adverse health effects are unlikely to occur after chronic (lifetime) exposure. If exceeded, it serves as an indicator of the potential need for further action.

**Non-Detect (ND)** – No trace of the contaminant was present.

As you view the following water quality analysis tables, please recognize the following:

MassDEP has reduced the monitoring requirements for Synthetic Contaminants (SOC's) at four of our sources, as the sources are not at risk of contamination. The last sample for SOC's at these four sources was taken in the fourth quarter of 2018 and were found to meet all applicable US EPA and MassDEP standards.

MassDEP has reduced the monitoring requirements for Inorganic Contaminants (IOC's) at four of our sources, as the sources are not at risk of contamination. The last sample for IOC's at these four sources was taken on 2/13/20 and 6/11/20 and were found to meet all applicable US EPA and MassDEP standards.

**PFAS6 (Per- and Polyfluoroalkyl Substances)** – MassDEP has established a state MCL of 20 parts per trillion of the six contaminants combined. Per the regulation, the Edgartown Water Department was to comply with PFAS6 monitoring beginning in October of 2021. As a proactive measure, the Edgartown Water Department elected to voluntarily sample for these contaminants prior to our required compliance period. PFAS6 samples were collected and analyzed from all sources in December of 2020, with all results coming back **Non-Detect**. Due to this effort, compliance sampling for PFAS6 was waived in 2021 and the samples of 2020 met the 2021 PFAS6 sampling requirement. As per our sampling schedule, PFAS6 analysis was performed on all sources in 2022, with all results being **NON-DETECT**. A waiver for PFAS6 sampling has since been requested and granted, with our next sampling event scheduled for July of 2024.

EDGARTOWN WATER DEPARTMENT  
58 KAVANAGH WAY  
EDGARTOWN, MA 02539 (508) 627-4717  
PWS ID #4089000

**WATER QUALITY TESTING RESULTS**

The following tables list our 2022 or most recent water quality analysis. Every contaminant that was detected in the water, even in the most minute traces, is listed here. In total, more than 712 samples were collected and analyzed in 2022. Additionally, the water chemistry of all sources is monitored 24/7/365. The tables indicate the name of each contaminant detected, the highest allowable amount by regulation (MCL), the ideal goal for public health, the amount detected, the usual sources of the contaminant and footnotes. The presence of these contaminants in the water does not necessarily indicate that the water poses a health threat. ***In 2022, the water produced by Edgartown Water Department met or exceeded all state and federal health requirements.*** Please note: As per MassDEP reporting regulations, the data in this table is from the most recent analysis of specific contaminants as dictated by our MassDEP Sampling Schedule.

Contaminants								
REGULATED SUBSTANCES								
<i>Inorganic Contaminants</i>	Date Tested	Units of Measure	MCL	MCLG	Highest Level Detected	Range Detected	Possible Source(s) of Contamination	Violation YES / NO
Asbestos	2022	MFL	7		ND	ND	Naturally present in the environment /	NO
Nitrate	2022	ppm	10	10	0.79	0.10 - 0.79	Runoff from fertilizer use, leaching from septic tanks, sewerage, naturally present	NO
Arsenic	2020	ppm	0.01	N/A	0.001	ND – 0.001	Naturally present in the environment	NO
Barium	2020	ppm	2	2	0.019	0.003 - 0.019	Naturally present in the environment	NO
<i>Radioactive Contaminants</i>	Date Tested	Units of Measure	MCL	MCLG	Highest Level Detected	Range Detected	Possible Source(s) of Contamination	Violation YES / NO
Gross Alpha Activity	2021	pC/L	15	0	2.48	0.056 – 2.48	Erosion of natural deposits	NO
Radium 226 / 228	2021	pC/L	5	0	1	0.44 – 1.00	Erosion of natural deposits	NO
<i>Volatile Organic Contaminants</i>	Date Tested	Units of Measure	MCL	MCLG	Highest Level Detected	Range Detected	Possible Source(s) of Contamination	Violation YES / NO
Chloroform	2022	ppb	*	*	3.81	0.89 - 3.81	Erosion of natural deposits	NO
Tetrachloroethylene (PCE)	2022	ppb	5	0	1.05	ND – 1.05	Residual of vinyl lined water mains	NO

EDGARTOWN WATER DEPARTMENT  
 58 KAVANAGH WAY  
 EDGARTOWN, MA 02539 (508) 627-4717  
 PWS ID #4089000

UNREGULATED SUBSTANCES	Date Tested	Units of Measure	SMCL	ORSG	Highest Level Detected	Range Detected	Possible Source(s) of Contamination	Violation YES / NO
Manganese	2020	ppm	0.05		0.033	ND – 0.033	Naturally present in the environment	NO
Sodium	2017	ppm	20 *	17.6	25.2	10.0 – 25.2	Naturally present in the environment	NO
<i>Lead / Copper **</i>	Date Tested	Units of Measure	AL		90 <sup>th</sup> Percentile	Range Detected	Possible Source(s) Contamination	Violation YES / NO
Lead **	2022	ppm	0.015	0	0.0016	ND – 0.005	Corrosion of household plumbing	NO
Copper **	2022	ppm	1.3	1.3	0.302	0.01 - 0.45	Corrosion of household plumbing	NO

\*MassDEP ORSG established

\*\* Tap water samples were collected for lead and copper analysis from 30 homes throughout the service area

**Early Learning Facilities:**

<i>Lead / Copper</i>	Date Tested	Units of Measure	Lead	Copper	Possible Source(s) Contamination	Violation YES / NO
Edgartown Elementary kitchen	2022	mg /L	ND	0.012	Corrosion of household plumbing	NO
Edgartown Elementary bathroom	2022	mg/L	ND	0.011	Corrosion of household plumbing	NO

<i>Lead / Copper</i>	Date Tested	Units of Measure	Lead	Copper	Possible Source(s) Contamination	Violation YES / NO
Rainbow Place kitchen	2022	mg /L	ND	0.204	Corrosion of household plumbing	NO
Rainbow Place back hall	2022	mg/L	ND	0.015	Corrosion of household plumbing	NO

EDGARTOWN WATER DEPARTMENT  
58 KAVANAGH WAY  
EDGARTOWN, MA 02539 (508) 627-4717  
PWS ID #4089000

SECONDARY CONTAMINANTS	Date Tested	Units of Measure	SMCL	MDL Mg / L	Highest Level Detected	Range Detected	Possible Source(s) of Contamination	Violation YES / NO
Iron	2022	mg/L	0.3	0.01	0.64	0.04 – 0.64	Naturally present in the environment	NO***
Manganese	2022	mg/L	0.05	0.005	0.038	0.006 – 0.038	Naturally present in the environment	NO
Alkalinity	2022	mg/L	NONE	1.0	28.8	8.39 – 28.8	Naturally present in the environment	NO
Calcium	2022	mg/L	NONE	0.1	3.4	1.1 – 3.4	Naturally present in the environment	NO
Magnesium	2022	mg/L	NONE	0.1	3.5	1.4 – 3.5	Naturally present in the environment	NO
Hardness	2022	mg/L	NONE	3.0	23.0	8.5 – 23.0	Naturally present in the environment	NO
Potassium	2022	mg/L	NONE	0.1	2.0	1.4 – 2.0	Naturally present in the environment	NO
Chloride	2022	mg/L	250	3.0	24.6	13.6 – 24.6	Naturally present in the environment	NO
Copper	2022	mg/L	1.0	0.003	0.035	ND – 0.035	Naturally present in the environment	NO
Sulfate	2022	mg/L	250	3.0	6.5	3.2 – 6.5	Naturally present in the environment	NO
Conductance	2022	umhos/cm	500	5.0	118	62.7 – 118	Naturally present in the environment	NO
Zinc	2022	mg/L	5	0.004	0.020	0.004 - 0.020	Naturally present in the environment	NO
Turbidity	2022	mg/L	NONE	1.0	<1.0	<1.0	Naturally present in the environment	NO
Aluminum	2022	mg/L	0.2	0.010	0.056	0.012 – 0.056	Naturally present in the environment	NO
Silver	2022	mg/L	0.10	0.002	ND	ND	Naturally present in the environment	NO

**SMCL Violations:** \*\*\* Secondary Samples are not required, but are recommended to monitor water quality aesthetics. Machacket Well produced a result of 0.64 mg/L. However, this well is reserved for emergency use and the water does not enter the distribution system and therefore, does not constitute a violation and further, **this sample did not represent a public health threat.**

**MCL Violations:** All water contains a number of dissolved mineral and organic substances. The presence of contaminants in drinking water does not mean your water is not safe. Federal and state drinking water standards establish limits, or Maximum Contaminant Levels (MCLs), for substances that might affect health or aesthetic qualities of water. **The Edgartown Water Department did not experience any MCL violations in 2022.**

**Cross Connection Program**

In addition to the obvious sources of contamination, a water system is also susceptible to cross connections. A cross connection is a direct or indirect connection of a hazardous or potentially hazardous substance with the potable water supply. Cross connections are not necessarily intended or malicious; they most often occur unintentionally, given the proper conditions. Should the proper conditions exist, there is a potential for contamination or contaminated water to backflow or back-siphon into the public water system. Examples of devices that should be isolated from the potable water supply may include lawn irrigation systems, fire protection systems, air conditioning or cooling systems, as well as high-pressure boilers. The Edgartown Water Department would like you to know that unprotected cross connections may contaminate the water in your home, as well as the municipal water system. The water system maintains a degree of protection by means of a check valve at the meter. However, this device does not provide adequate protection of the public water system from high hazard facilities or appliances and it provides no protection within your home. If you require additional information on this topic, please contact our office.

CONSERVATION AND ENVIRONMENTAL EFFORTS

---

**Voluntary Water Conservation Measures:**

Municipal water systems face many challenges such as meeting seasonal water demands, the acquisition of additional supplies to meet the demands of growth, resource protection, water conservation, environmental protection, and the increasingly more stringent regulations for water quality. Our sustainability, as it relates to water, is dependent on our ability to stay abreast of changing conditions and the implementation of future plans. Therefore, sound planning and management are crucial. Regardless of our future supply conditions, water conservation and prudent supply management will still be a main priority to ensure long-term availability of our water supplies. We are committed to conserving our water supplies and complying with regulatory requirements governing the operation of water systems. The implementation of Voluntary Water Conservation Measures will achieve the two goals of regulatory compliance and water conservation. A conscientious effort on everyone's part is essential in making these conservation measures effective. Your efforts are most appreciated, as we must all work together to preserve this most valuable resource for generations to come. Municipal water systems are subject to fines, should water withdrawal limitations be exceeded. Consequently, the Edgartown Water Department has implemented the following Voluntary Water Conservation Measures to be effective from May through September:

- Watering of lawns is limited to odd / even days (based on house address) between the hours of 7:00 p.m. and 7:00 am.
- Washing of sidewalks, patios and driveways is prohibited (excluding businesses for health / safety reasons)
- Pistol-grip nozzles are to be used on all hoses used for washing cars and on hoses at dockside facilities.
- Restaurants may serve water upon request of the patron.

**Your recognition of and participation in this voluntary program is most appreciated!!!!**

**Leak Detection:**

The Edgartown Water Department is constantly trying to operate in the most fiscally responsible and environmentally friendly fashion. In addition, we strive to meet or exceed regulatory standards pertaining to water conservation. Water systems are expected to remain under 10% unaccounted for water (water that is not metered, such as leaks). It is for these reasons that we routinely conduct full or partial leak detection surveys of the distribution system. In 2022, we conducted leak detection on the entire distribution system, with no leaks discovered / repaired. Prior to this, the last full leak detection survey was conducted in 2018. In 2022, we had a respectable 4.7% unaccounted for water. In comparison to all of the other water systems within the Commonwealth, this is exceptionally low. We intend to continue to systematically proceed through the distribution system and check for leaks within our infrastructure on an annual basis. If leaks are detected, they will be repaired as soon as practical. By tightening up the distribution system, we will pump less water, use less electricity, minimize operational expenses, meet regulatory standards and stay within our withdrawal limitations.

**Protection of Water Sources:**

The Edgartown Water Department has taken an active approach in protecting its five groundwater supply sources. In accordance with regulatory standards, the immediate and surrounding areas proximate to each source are monitored and controlled to minimize the exposure to potential threats and contaminants. In addition to the oversight of our personnel, the wells and their surrounding areas are routinely inspected by MassDEP.

**SWAP (Source Water Assessment and Protection):**

The MassDEP has prepared a Source Water Assessment Protection Report for the Edgartown Water Department. The report assesses the susceptibility of public water supplies to contamination and it makes recommendations based on the findings. The report is available on the MassDEP website at:

<http://www.mass.gov/eea/docs/dep/water/drinking/swap/sero/4089000.pdf>.

EDGARTOWN WATER DEPARTMENT  
58 KAVANAGH WAY  
EDGARTOWN, MA 02539 (508) 627-4717  
PWS ID #4089000

**Hazardous Household Waste Disposal:**

The proper disposal of household products is important to keep water supplies and the environment contaminant free. The Martha's Vineyard Refuse Disposal & Resource Recovery District accepts many hazardous household products such as used motor oil, oil based paints, stains, thinners, and other hazardous waste. Products may be disposed of FREE OF CHARGE on May 20<sup>th</sup>, July 15<sup>th</sup> and October 21<sup>st</sup> between the hours of 9:00 a.m. and 12:00 noon. They are located at 750 West Tisbury Road in Edgartown, MA. For additional information, please call the Martha's Vineyard Refuse Disposal & Resource Recovery District at (508) 627-4501 or consult their website at mvrefusedistrict.com. Please Note: Commercial users or those with large quantities are requested to call in advance so that proper provisions may be made.

---

ADDITIONAL INFORMATION / QUESTIONS

---

Should you have any comments, questions or concerns with regard to this report, or the water system in general, please contact William R. Chapman at the Edgartown Water Department at (508) 627-4717 between the hours of 8:00 a.m. and 4:00 p.m., Monday through Friday or at:

Edgartown Water Department  
P.O. Box 238  
Edgartown, MA 02539

Additional information about the Edgartown Water Department may be obtained by consulting our website at <http://www.townofedgartown-ma.us>.

Water quality data for communities throughout the United States is also located at [www.waterdata.com](http://www.waterdata.com). The Public Water System Identification Number (PWSID) for the Edgartown Water Department is 4089000.

If you would like to participate in discussions regarding your water quality or the operations of the Edgartown Water Department, you may attend the monthly Board of Water Commissioners meetings. Regular Commissioner's meetings occur on the second Tuesday of every month at 3:00 p.m. at the Water Department office located at 58 Kavanagh Way. Public involvement and participation are encouraged and is welcome.

**Board of Water Commissioners**

David Burke – Commissioner \*\*\*

James Kelleher – Commissioner \*\*\*

Scott Ellis – Commissioner

\*\*\* Served as Chair during CY 2022



EDGARTOWN WATER DEPARTMENT  
58 KAVANAGH WAY  
EDGARTOWN, MA 02539 (508) 627-4717  
PWS ID #4089000